

# EQUIPMENT SCHEDULE

---

- Ⓐ ELECTRIC FIRE PUMP 30HP 480V 3PH – 1000 GPM AT 40 PSI
- Ⓑ FIRE PUMP CONTROLLER WITH LOW FUEL ALARM  
AND LOW ROOM TEMPERATURE ALARM
- Ⓒ JOCKEY PUMP 3/4HP 480V 3PH – 2 GPM AT 40 PSI
- Ⓓ JOCKEY PUMP CONTROLLER
- Ⓔ FLOW METER UL/FM APPROVED
- Ⓕ CONCENTRIC REDUCER
- Ⓖ ECCENTRIC INCREASER
- Ⓗ CASING RELIEF VALVE
- Ⓘ ORIFICE UNION

”A TYPICAL EQUIPMENT SCHEDULE”

---

---

CITY OF RALEIGH FIRE DEPARTMENT  
FIRE PROTECTION DIVISION  
310 WEST MARTIN ST. RALEIGH, NC 27602

DESCRIPTION:  
EQUIPMENT SCHEDULE

REVISIONS:  
5-1-2017

DATE:  
5/1/06

DRAWING NO.  
FP-10