



**TYPICAL NOTES:**

- 1)-ALL EXPOSED PIPING AND FITTINGS TO BE GALVANIZED WITH EXCEPTION OF STORZ CONNECTION
- 2)-40' MAX. FROM FDC TO APPARATUS ACCESS LOCATION
- 3)-FOR NFPA 13R SYSTEMS (2 1/2" RISER AND SMALLER) SINGLE FDC
- 4)-FOR HIGH RISE BUILDINGS USE SIAMESE

CITY OF RALEIGH FIRE DEPARTMENT  
 FIRE PROTECTION DIVISION  
 310 WEST MARTIN ST. RALEIGH, NC 27602

DESCRIPTION:  
 FLUSH FDC DETAIL REQUIRMENTS

REVISIONS:  
 5/1/2017

DATE:  
 5/1/06

DRAWING NO.  
 FP-14