




SPRINKLER LEGEND

○	EXISTING SPRINKLER	1/2" / 155° / SSP / 5.6K / TOTAL 250 /
R⊗	EXISTING SPRINKLER TO BE REMOVED & PLUGGED	___ / ___ / ___ / ___ / TOTAL 10 /
 ○	EXISTING SPRINKLER TO BE RELOCATED	___ / ___ / ___ / ___ / TOTAL 30 /
●	NEW CHROME PENDENT SPRINKLER VIKING FAST-RESPONSE MODEL M WITH MODEL F1 CHROME ESCUTCHEON	1/2" / 155° / SSP / 5.6K / TOTAL 16 /
○	NEW BRASS UPRIGHT SPRINKLER CENTRAL MODEL A	3/4" / 165° / SSU / 8.0K / TOTAL 20 /
◁	NEW CHROME HORIZONTAL SIDEWALL SPRINKLER	1/2" / 165° / <u>QR</u> / 5.5K / TOTAL 6 /
⊙	New Extended Coverage Pendent Semi Recessed	3/4" / 155° / SSP / 11.4K / TOTAL 28 /
QR ●	New Chrome Pendent Sprinkler Quick Response	1/2" / 155° / QR / 5.5K / TOTAL 10 /
ES ●	New ESFR Upright Sprinkler	1" / 155° / ESFR / 25.2K / TOTAL 30 /

————	EXISTING PIPE
—×××—	EXISTING PIPE TO BE REMOVED
————	NEW PIPE
	2-HOUR RATED FIRE WALL
	1-HOUR RATED FIRE WALL

CITY OF RALEIGH FIRE DEPARTMENT
FIRE PROTECTION DIVISION
310 WEST MARTIN ST. RALEIGH, NC 27602

DESCRIPTION:
SPRINKLER LEGEND TYPICAL

REVISIONS:
5-1-2017

DATE:
5/1/06

DRAWING NO.
FP-9