



- NOTE:**
1. AIR VALVE TO BE P-20 WITH VACUUM CHECK BY CRISPIN OR VALMATIC VM 45.
 2. THE AIR RELEASE MANHOLE SHALL BE INSTALLED IN THE SHOULDER OR AS DIRECTED BY THE ENGINEER.
 3. FOR MAINS LOCATED OUTSIDE OF STREET RIGHT-OF-WAYS THE MAXIMUM DISTANCE BETWEEN THE MANHOLE AND THE VALVE BOX SHOULD BE THREE (3) FEET.
 4. MAIN SHALL BE DEEP ENOUGH TO ACCOMMODATE INSTALLATION AS SHOWN

BILL OF MATERIALS

BILL OF MATERIALS	
1	PRECAST MANHOLE, SEE STANDARD DETAIL S-20
2	TRASH HOOD
3	2" AIR RELEASE VALVE
4	2" CURB STOP BALL VALVE
5	ADAPTER
6	2" MECHANICAL JOINT BRASS PIPE AND FITTINGS
7	2" TYPE 'K', SOFT COPPER WITH FLARED ELBOW
8	CORPORATION COCK
9	6" DIAMETER DRAIN
10	GROUT, 1/8" TO 1'-0" MIN. SLOPE TO DRAIN
11	PIPE CAP
12	2'-GATE VALVE

SEE STANDARD DETAIL R-3 AND R-3A TO INSURE PROPER BACKFILL.

CITY OF RALEIGH				
DEPARTMENT OF PUBLIC UTILITIES				
STANDARD REUSE AIR RELEASE VALVE				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
R-16	ABB	10-4-04	RRH J.P.S.	6-7-00 10-20-10