



NOTES:

- 1) RECLAIMED WATER METER SHALL NOT BE LOCATED IN AREAS SUBJECT TO VEHICULAR TRAFFIC.
- 2) ALL METER BOXES SHALL BE AS MANUFACTURED WITH HEAVY DUTY RATED LOCKING POLYMER CEMENT COVER AS APPROVED BY CORPUD.
- 3) METER & SIZER SHALL BE INSTALLED AND ANCHORED IN CENTER OF BOX.
- 4) THE INTERIOR OF THE BOX SHALL BE STENCILED WITH THE WORDS, CAUTION RECLAIMED WATER - DO NOT DRINK.
- 5) ALL RELOCATIONS OF EXISTING OR PERMITTED RECLAIMED WATER INFRASTRUCTURE INCLUDING SERVICE PIPING AND METER BOXES SHALL BE PERMITTED AND INSPECTED.
- 6) CURB STOP BOX SHALL HAVE PLUG STYLE LID WITH PENTAGON BOLT 1-1/4" STEEL UPPER SECTION, AND ARCH STYLE BASE. STEEL STATIONARY ROD TO BE PROVIDED FOR CURB STOP OPERATION.
- 7) 1" BRASS CURB STOP WITH CURB STOP VALVE BOX SET TO GRADE, WITHIN 1' OF METER BOX.

**** ADDED CURB STOP AND NOTE #5 AND #6**

CITY OF RALEIGH			
DEPARTMENT OF PUBLIC UTILITIES			
STANDARD 1" RECLAIMED WATER SERVICE			
# METER BOX INSTALLATION			
DWG. NO.	REVISIONS:	DATE:	REVISIONS:
R-18	DHL	6/18/08	
	J.P.S.	10-20-10	