



NOTES:

1. PUMP STATION MUST MEET ALL ZONING SET-BACK REQUIREMENTS
2. PUMP STATION MUST MEET ALL LANDSCAPING REQUIREMENTS
3. WATER SERVICE FOR YARD HYDRANT MUST HAVE RPZ BACKFLOW PROTECTION. SIZE OF SERVICE MAY VARY
4. PUMP STATION EASEMENT TO BE 60'x 60' MINIMUM
5. EQUIPMENT LOCATIONS MAY VARY
6. 5' BUFFER SHALL BE REQUIRED BETWEEN FENCE AND EASEMENT LINE.

* FOR ELECTRICAL PANEL REFER TO DETAILS S-36 & S-37

CITY OF RALEIGH				
DEPARTMENT OF PUBLIC UTILITIES				
MINIMUM REQUIREMENTS FOR PUMP STATIONS				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-35	D.W.C.	10-1-99	A.B.B.	2-16-05
	RRH	3-30-00		