



NOTES:

1. Trenches requiring shoring and bracing, dimensions shall be taken from the inside face of the shoring and bracing.
2. No rocks or boulders 4" or larger to be used in backfill.
3. All backfill material shall be suitable native material.
4. Backfill shall be tamped in 6" lifts.
5. Achieve 95% compaction in backfill.

CITY OF RALEIGH				
DEPARTMENT OF PUBLIC UTILITIES				
TRENCH BOTTOM DIMENSIONS & BACKFILLING REQUIREMENTS FOR DUCTILE IRON				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
W-3		3-1-87	RRH	3-31-00
	D.W.C.	9-3-99	ABB	2-15-05