



NOTES:

1. See City of Raleigh standards for trenches and pipe bedding W-3 for additional details
2. Pavement cuts within NCDOT ROW shall conform to the approved on site encroachment permit.
3. The pavement cut shall be defined by a straight edge and cut with an approved saw cut machine.
4. The trench subgrade material shall be backfilled with suitable material and compacted to a density of at least 95% of that obtained by compacting a sample of the material in accordance with AASHTO T-99 as modified by NCDOT.
5. The final 6" of fill shall consist of ABC material compacted to a density equal to 100% of that obtained by compacting a sample of the material in accordance with AASHTO T-80 as modified by NCDOT.

CITY OF RALEIGH				
DEPARTMENT OF PUBLIC UTILITIES				
STANDARD CONCRETE				
PAVEMENT PATCH DETAIL				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
W-1	RRH	3-31-00		
	A.B.B.	2-8-05		