

- Code Interpretation : Plumbing
- Subject: Oil Interceptors
- Code Reference: 1999 Volume II NCPC/2002 NCPC
- Effective Date: Sept. 2001 and 2002 Code Cycle

Code:

Volume II section 1004.1 and 2002 NCPC section 1003.5 where required

Interceptors or separators shall be provided where, in the opinion of the plumbing official, they are necessary for the proper handling of wastes containing ingredients harmful to the building drainage system, the public sewer, or sewage treatment plant.

Interpretation:

Elevator pits: The interceptor must be sized to store the max amount of hydraulic fluid as stated on plans or shall have a draw off tank to store the max amount of hydraulic fluid. The draw off tank must be accessible for servicing. The interceptor must be fed with a water source for separation to take place.

For other sizing design requirements **The 2000 International Plumbing Code** without NC amendments. **Section 1003.4.2 General Design requirements and 1003.4.2.2 Garages and service stations,** may be used as sizing requirements

City of Raleigh
 Inspections Department
 P.O.Box 590
 222W. Hargett St
 Raleigh, N.C.27602

9/17/01