



1. HOLE SHALL BE CORED IN RISER SECTION FOR PUBLIC SERVICE MAIN EXTENSION.
2. RUBBER BOOT SHALL BE UTILIZED ON ALL CORES
3. CORES SHALL BE IN CENTER OF RISER SECTION
4. CONNECTION TO TEE MANHOLE MUST BE MADE BY CONTRACTOR APPROVED BY CITY OF RALEIGH PUBLIC UTILITIES DEPARTMENT

CITY OF RALEIGH				
DEPARTMENT OF PUBLIC UTILITIES				
MAIN EXTENSION TO TIE INTO TEE MANHOLE				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-33	D.W.C.	6-99	ABB	2-14-05
	RRH	3-30-00	D.H.L.	6-18-08